CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/WNo.10/KRIDL/CSR-08/123i/CEMENT/2016-17 Date: 22.08.2016

TEST REPORT ON CEMENT

* CUSTOMER	:	**Asst. Executive Engineer,** Vidyaranyapura Sub Division, BBMP, Bangalore.
*AGENCY	:	**Executive Engineer,** KRIDL, Bangalore.
*NAME OF THE WORK	:	Improvements to roads and drains at Gangamma Gudi Area in Ward No. 10, BBMP, Bangalore.
REFERENCE	:	BBMP/AEE/VSD/50/2016-17 Dated: 20.08.2016
SAMPLE ID	:	Cement – Sample 2
SAMPLE RECEIVED ON	:	20.08.2016
PERIOD OF TESTING	:	20.08.2016 to 22.08.2016

The results of the tests conducted on the cement sample are as follows:

Sl. No	Descriptions	Test Method as per IS	Test Result	Requirements as per IS: 8112-2013
1	Standard Consistency	IS-4031 (Part -4) 1988(RA-2009)	28.50%	-
2	a) Initial Setting Time	IS-4031 (Part -5) 1988(RA-2009)	135 Minutes	Not Less than 30 Minutes
	b) Final Setting Time	IS-4031 (Part -5) 1988(RA-2009)	465 Minutes	Not More than 600 Minutes
3	Soundness by Le Chartlier Method	IS-4031 (Part-3) 1988(RA-2009)	1 mm	Not more than 10mm

*Information is furnished by the Customer/Representative.

AE-10

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

Sadha
AE

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/WNo.10/KRIDL/CSR-08/123i/SAND-Gradation/2016-17 : 22.08.2016

TEST REPORT ON DETERMINATION GRADATION OF FINE AGGREGATES

*** Customer** : **Asst. Executive Engineer,** Vidyaranyapura Sub Division, BBMP, Bangalore.

*** Agency** : **Executive Engineer,** KRIDL, Bangalore.

*** Name of Work** : Improvements to roads and drains at Gangamma Gudi Area in Ward No. 10, BBMP, Bangalore.

Reference : BBMP/AEE/VSD/50/2016-17 Dated: 20.08.2016

Technical Reference : IS : 2386 Part 1 - 1963 RA-2007

Sample ID : Fine Aggregates - Sample 2

Sample Received on : 20.08.2016

Date of Testing : 22.08.2016

Total Wt. of Aggregates in gms **1000**

Is Sieve Size in mm	Cumulative Weight Passing in %	Spec.Limits as per IS 383-1970 (RA- 2007)			
		Zone-I	Zone-II	Zone-III	Zone-IV
10	100	100	100	100	100
4.75	92.75	90-100	90-100	90-100	95-100
2.36	78.59	60-95	75-100	85-100	95-100
1.18	58.03	30-70	55-90	75-100	90-100
600 Micron	38.46	15-34	35-59	60-79	80-100
300 Micron	15.93	5-20	8-30	12-40	15-50
150 Micron	2.94	0-10	0-10	0-10	0-15

* Information is furnished by the Customer/Representative

Remarks : This sample is under Zone-II specific limits.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

Jadhav
AE

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/WNo.10/KRIDL/CSR-08/123i/AGG/GR/2016-17 : 22.08.2016

TEST REPORT ON COARSE AGGREGATES

* Customer	: **Asst. Executive Engineer,** Vidyaranyapura Sub Division, BBMP, Bangalore.
* Agency	: **Executive Engineer,** KRIDL, Bangalore.
* Name of Work	: Improvements to roads and drains at Gangamma Gudi Area in Ward No. 10, BBMP, Bangalore.
Reference	: BBMP/AEE/VSD/50/2016-17 Dated: 20.08.2016
Technical Reference	: IS : 2386 Part 1 -1963 RA-2007
Sample ID	: Coarse Aggregates (40mm) - Sample 2
Sample Received on	: 20.08.2016
Date of Testing	: 22.08.2016

Total Wt. of Aggregates in gms= **7000**

Is Sieve Size in mm	Cumulative Weight Passing in %	Spec.Limits as per IS 383-1970 (RA- 2007)	
		Graded	Single Sized
80	100	100	-
63	100	-	100
40	97.09	95-100	85-100
20	33.71	30-70	0-20
10	12.37	10-35	0-5
4.75	1.54	0-5	-

* Information is furnished by the Customer/Representative

Remarks : This sample is under Graded specific limits.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

Civil-Tech Consultants & Engineers Bangalore

VISHWANATH .C
Quality Manager

Jadhav
AE

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/WNo.10/KRIDL/CSR-08/123i/AGG/GR/2016-17 : 22.08.2016

TEST REPORT ON COARSE AGGREGATES

* **Customer**	: **Asst. Executive Engineer,** Vidyaranyapura Sub Division, BBMP, Bangalore.
* **Agency**	: **Executive Engineer,** KRIDL, Bangalore.
* **Name of Work**	: Improvements to roads and drains at Gangamma Gudi Area in Ward No. 10, BBMP, Bangalore.
Reference	: BBMP/AEE/VSD/50/2016-17 Dated: 20.08.2016
Technical Reference	: IS : 2386 Part 1 -1963 RA-2007
Sample ID	: Coarse Aggregates (20mm) - Sample 2
Sample Received on	: 20.08.2016
Date of Testing	: 22.08.2016

Total Wt. of Aggregates in gms= **5000**

Is Sieve Size in mm	Cumulative Weight Passing in %	Spec.Limits as per IS 383-1970 (RA- 2007)	
		Graded	Single Sized
40	100	100	100
20	97.08	95-100	85-100
10	30.12	25-55	0-20
4.75	2.94	0-10	0-5

* Information is furnished by the Customer/Representative

Remarks : This sample is under Graded specific limits

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

Jadhav
AE

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

JAS-ANZ BSCIC ISO 9001 REGISTERED

Job No.: CTCE/BBMP/WNo.10/KRIDL/STEEL/2016-17 23.08.2016

TEST REPORT ON REINFORCEMENT STEEL

Customer	:	**Asst. Executive Engineer,** Vidyaranyapura Sub Division, BBMP, Bangalore.
Agency	:	**Executive Engineer,** KRIDL, Bangalore.
Name of the Work	:	Improvements to roads and drains at Gangamma Gudi Area in Ward No. 10, BBMP, Bangalore.
Reference	:	BBMP/AEE/VSD/50/2016-17 Dated: 20.08.2016
Date of Test	:	23.08.2016
Technical Reference	:	IS: 1786-2008

Sl. No	Nominal size (dia) (mm)	Mass per metre (Kg/mtr)	TENSILE STRENGTH			Bend Test	Rebend Test
			0.20% proof stress/Yield stress N/mm^2	Tensile strength (Ultimate stress) N/mm^2	Elongation percent gauge length		
1	8	0.40	512	553	13.05	O.K	O.K

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 30 days from the date of testing.

****

M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

Jadhav
AE

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

JAS-ANZ BSCIC ISO 9001 REGISTERED

Job No.: CTCE/BBMP/WNo.10/KRIDL/STEEL/2016-17 23.08.2016

TEST REPORT ON REINFORCEMENT STEEL

Customer	:	**Asst. Executive Engineer,** Vidyaranyapura Sub Division, BBMP, Bangalore.
Agency	:	**Executive Engineer,** KRIDL, Bangalore.
Name of the Work	:	Improvements to roads and drains at Gangamma Gudi Area in Ward No. 10, BBMP, Bangalore.
Reference	:	BBMP/AEE/VSD/50/2016-17 Dated: 20.08.2016
Date of Test	:	23.08.2016
Technical Reference	:	IS: 1786-2008

Sl. No	Nominal size (dia) (mm)	Mass per metre (Kg/mtr)	TENSILE STRENGTH			Bend Test	Rebend Test
			0.20% proof stress/Yield stress N/mm^2	Tensile strength (Ultimate stress) N/mm^2	Elongation percent gauge length		
1	10	0.62	514	558	13.25	O.K	O.K

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 30 days from the date of testing.

M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

****

Sadha
AE

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

JAS-ANZ BSCIC ISO 9001 REGISTERED

Job No.: CTCE/BBMP/WNo.10/KRIDL/STEEL/2016-17 23.08.2016

TEST REPORT ON REINFORCEMENT STEEL

Customer	:	**Asst. Executive Engineer,** Vidyaranyapura Sub Division, BBMP, Bangalore.
Agency	:	**Executive Engineer,** KRIDL, Bangalore.
Name of the Work	:	Improvements to roads and drains at Gangamma Gudi Area in Ward No. 10, BBMP, Bangalore.
Reference	:	BBMP/AEE/VSD/50/2016-17 Dated: 20.08.2016
Date of Test	:	23.08.2016
Technical Reference	:	IS: 1786-2008

Sl. No	Nominal size (dia) (mm)	Mass per metre (Kg/mtr)	TENSILE STRENGTH			Bend Test	Rebend Test
			0.20% proof stress/Yield stress N/mm^2	Tensile strength (Ultimate stress) N/mm^2	Elongation percent gauge length		
1	12	0.89	516	562	13.50	O.K	O.K

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 30 days from the date of testing.

Civil-Tech Consultants & Engineers Bangalore

****

M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

Jadhav
AE

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/WNo.10/KRIDL/CSR-08/123i/CUBE/2016-17 22.09.2016

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

* Customer	: **Asst. Executive Engineer,** Vidyaranyapura Sub Division, BBMP, Bangalore.
* Agency	: **Executive Engineer,** KRIDL, Bangalore.
* Name of the work	: Improvements to roads and drains at Gangamma Gudi Area in Ward No. 10, BBMP, Bangalore.
Reference	: BBMP/AEE/VSD/50/2016-17 Dated: 20.08.2016
* Sample ID	: RCC Drain Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
* Grade of Concrete	: M_{20}
Compressive Strength as on	: 28^{th} day
Sample Received on	: 22.09.2016

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	25.08.2016	22.09.2016	8.176	481.2	21.39
2	25.08.2016	22.09.2016	8.264	498.6	22.16
3	25.08.2016	22.09.2016	8.328	511.3	22.72

* Information is furnished by the Customer/Representative

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

Jadhav
AE

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/WNo.10/KRIDL/CSR-08/123i/CUBE/2016-17 27.09.2016

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

* Customer	: **Asst. Executive Engineer,** Vidyaranyapura Sub Division, BBMP, Bangalore.
* Agency	: **Executive Engineer,** KRIDL, Bangalore.
* Name of the work	: Improvements to roads and drains at Gangamma Gudi Area in Ward No. 10, BBMP, Bangalore.
Reference	: BBMP/AEE/VSD/50/2016-17 Dated: 20.08.2016
* Sample ID	: Culvert Deck Slab Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
* Grade of Concrete	: M_{20}
Compressive Strength as on	: 28^{th} day
Sample Received on	: 27.09.2016

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	30.08.2016	27.09.2016	8.289	478.2	21.25
2	30.08.2016	27.09.2016	8.338	489.7	21.76
3	30.08.2016	27.09.2016	8.452	505.6	22.47

* Information is furnished by the Customer/Representative

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

Jadhav
AE

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/WNo.10/KRIDL/CSR-08/123i/CUBE/2016-17 28.09.2016

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer**	: **Asst. Executive Engineer,** Vidyaranyapura Sub Division, BBMP, Bangalore.
*** Agency**	: **Executive Engineer,** KRIDL, Bangalore.
*** Name of the work**	: Improvements to roads and drains at Gangamma Gudi Area in Ward No. 10, BBMP, Bangalore.
Reference	: BBMP/AEE/VSD/50/2016-17 Dated: 20.08.2016
*** Sample ID**	: Road Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
*** Grade of Concrete**	: M_{20}
Compressive Strength as on	: 28^{th} day
Sample Received on	: 28.09.2016

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	31.08.2016	28.09.2016	8.178	473.6	21.05
2	31.08.2016	28.09.2016	8.275	491.4	21.84
3	31.08.2016	28.09.2016	8.346	515.7	22.92

* Information is furnished by the Customer/Representative

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

Sadha
AE

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com